

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-1429:114 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Secutron Inc., 70 Esna Park Dr., Unit 14, Markham, Ontario, Canada L3R 6E7
Contact: *Paul Mattern (978) 731-8542 Fax (978) 731-8881

DESIGN: Models MR-2602, MR-2602-240, MR-2605, MR-2605-240 fire alarm control unit. Power-limited; non-coded, local, central station (PPU), remote station (PPU), manual, automatic, waterflow and sprinkler supervisory service. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

MR-2605-R3	Relay Module
MR-2806	Dual Line Dialer
MR-2602A	2-Zone Input Module
MR-2605A	5-Zone Input Module
MR-2602-AT	2-Zone Remote Annunciator
MR-2605-AT	5-Zone Remote Annunciator
MR-2605T	Trouble Remote Annunciator

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings, and UL Inc. Label

APPROVAL: Listed as a fire alarm control unit for use with separately listed compatible initiating and indicating devices.

These control units can generate the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition. Refer to manufacturer's Installation Manual for details.

NOTE: For **Fire Alarm Verification Feature**, the maximum Retard/Reset/Restart period must be adjusted to 30 seconds or less.

*Rev. 09-12-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 17, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager